



SWEDISH  
STANDARDS  
INSTITUTE

# SVENSK STANDARD SS-EN ISO 15876-1:2004

Fastställd 2004-01-09

Utgåva 1

**Plaströrsystem för varm- och kallvatten-  
installationer – Material PB –**  
Del 1: Allmänt (ISO 15876-1:2003)

**Plastics piping systems for hot and cold  
water installations – Polybutylene (PB) –**  
Part 1: General (ISO 15876-1:2003)

ICS 23.040.01; 91.140.60

Språk: engelska

Publicerad: februari 2004

Europastandarden EN ISO 15876-1:2003 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN ISO 15876-1:2003.

The European Standard EN ISO 15876-1:2003 has the status of a Swedish Standard. This document contains the official English version of EN ISO 15876-1:2003.

---

Uppllysningar om **sakinnehållet** i standarden lämnas av SIS, Swedish Standards Institute, telefon 08 - 555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar **allmänna uppllysningar** om svensk och utländsk standard.

*Postadress:* SIS Förlag AB, 118 80 STOCKHOLM  
*Telefon:* 08 - 555 523 10. *Telefax:* 08 - 555 523 11  
*E-post:* [sis.sales@sis.se](mailto:sis.sales@sis.se). *Internet:* [www.sis.se](http://www.sis.se)

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN ISO 15876-1**

December 2003

ICS 23.040.01; 91.140.60

English version

**Plastics piping systems for hot and cold water installations -  
Polybutylene (PB) - Part 1: General (ISO 15876-1:2003)**

Systèmes de canalisations en plastique pour les  
installations d'eau chaude et froide - Polybutène (PB) -  
Partie 1: Généralités (ISO 15876-1:2003)

Kunststoff-Rohrleitungssysteme für die Warm- und  
Kaltwasserinstallation - Polybuten (PB) - Teil 1:  
Allgemeines (ISO 15876-1:2003)

This European Standard was approved by CEN on 17 March 2003.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: rue de Stassart, 36 B-1050 Brussels**

**EN ISO 15876-1:2003 (E)**

**Contents**

<b>Contents</b> .....	<b>2</b>
<b>Introduction</b> .....	<b>4</b>
<b>1 Scope</b> .....	<b>5</b>
<b>2 Normative references</b> .....	<b>5</b>
<b>3 Terms and definitions, symbols and abbreviated terms</b> .....	<b>5</b>
3.1 Terms and definitions .....	5
3.1.1 Geometrical terms and definitions.....	5
3.1.2 Terms and definitions related to service conditions .....	7
3.1.3 Terms and definitions related to material characteristics.....	8
3.2 Symbols.....	8
3.3 Abbreviated terms .....	9
<b>4 Classification of service conditions</b> .....	<b>9</b>
<b>5 Material</b> .....	<b>10</b>
5.1 General.....	10
5.2 Influence on water intended for human consumption .....	10
5.3 Crystallisation .....	11
5.4 Reprocessable material .....	11
<b>Bibliography</b> .....	<b>12</b>

## Foreword

This document (EN ISO 15876-1:2003) has been prepared by Technical Committee CEN/TC 155 "Plastics piping systems and ducting systems", the secretariat of which is held by NEN, in collaboration with Technical Committee ISO/TC 138 "Plastics pipes, fittings and valves for the transport of fluids".

NOTE This standard was submitted for CEN enquiry as prEN 12319-1:1996.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2004, and conflicting national standards shall be withdrawn at the latest by December 2005.

This standard is Part of a System Standard for plastics piping systems of a particular material for a specified application. There are a number of such System Standards.

System Standards are based on the results of the work undertaken in ISO/TC 138 "Plastics pipes, fittings and valves for the transport of fluids", which is a Technical Committee of the International Organisation for Standardization (ISO).

They are supported by separate standards on test methods to which references are made throughout the System Standard.

The System Standards are consistent with general standards on functional requirements and recommended practices for installation.

EN ISO 15876 consists of the following Parts <sup>1)</sup> under the general title: *Plastics piping systems for hot and cold water installations — Polybutylene (PB)*

- *Part 1: General* (the present standard)
- *Part 2: Pipes*
- *Part 3: Fittings*
- *Part 5: Fitness for purpose of the system*
- *Part 7: Guidance for the assessment of conformity* (CEN ISO/TS 15876-7).

This Part 1 of EN ISO 15876 includes a Bibliography.

At the date of publication of this standard, System Standards for piping systems of other plastics materials used for the same application are the following:

EN ISO 15874, *Plastics piping systems for hot and cold water installations — Polypropylene (PP)* (ISO 15874:2003)

EN ISO 15875, *Plastics piping systems for hot and cold water installations — Crosslinked polyethylene (PE-X)* (ISO 15875:2003)

EN ISO 15877, *Plastics piping systems for hot and cold water installations — Chlorinated poly(vinyl chloride) (PVC-C)* (ISO 15877:2003)

For pipes and fittings which have conformed to the relevant national standard before 1<sup>st</sup> November, 2003, as shown by the manufacturer or by a certification body, the national standard may continue to apply until 30<sup>th</sup> November, 2005.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and the United Kingdom.

---

1) This System Standard does not incorporate a Part 4 *Ancillary equipment* or a Part 6 *Guidance for installation*. For ancillary equipment separate standards can apply. A guidance for installation for plastics piping systems made from different materials, intended to be used for hot and cold water installations, is covered by ENV 12108 [1].

## EN ISO 15876-1:2003 (E)

### Introduction

The System Standard, of which this is Part 1, specifies the requirements for a piping system when made from polybutylene (PB). The piping system is intended to be used for hot and cold water installations.

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by EN ISO 15876:

- This standard provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- It should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

Requirements and test methods for components of the piping systems, are specified in Part 2 and Part 3 of EN ISO 15876:2003. Characteristics for fitness for purpose (mainly for joints) are covered in Part 5. Part 7 (CEN ISO/TS 15876-7) gives guidance for the assessment of conformity.

This Part of EN ISO 15876 specifies the general aspects of the plastics piping system.

## 1 Scope

This Part of EN ISO 15876 specifies the general aspects of polybutylene (PB) piping systems intended to be used for hot and cold water installations within buildings for the conveyance of water whether or not intended for human consumption (domestic systems) and for heating systems, under design pressures and temperatures according to the class of application (see Table 1).

This standard covers a range of service conditions (application classes) and design pressure and pipe dimension classes. For values of  $T_D$ ,  $T_{max}$  and  $T_{mal}$  in excess of those in Table 1, this standard does not apply.

NOTE It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and any relevant national regulations and installation practices or codes.

It also specifies the test parameters for the test methods referred to in this standard.

In conjunction with the other Parts of EN ISO 15876 (see Foreword) it is applicable to PB pipes, fittings, their joints and to joints with components of other plastics and non-plastics materials intended to be used for hot and cold water installations.

## 2 Normative references

This Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

EN ISO 15876-2:2003, *Plastics piping system for hot and cold water installations — Polybutylene (PB) — Part 2: Pipes (ISO 15876-2:2003)*

EN ISO 15876-3:2003, *Plastics piping system for hot and cold water installations — Polybutylene (PB) — Part 3: Fittings (ISO 15876-3:2003)*

ISO 472:1999, *Plastics — Vocabulary*

ISO 1043-1:2001, *Plastics — Symbols and abbreviated terms — Part 1: Basic polymers and their special characteristics*

## 3 Terms and definitions, symbols and abbreviated terms

For the purposes of this standard, the following terms and definitions, symbols and abbreviated terms apply.

### 3.1 Terms and definitions

In addition to the terms and definitions given below, the terms and definitions given in ISO 472:1999 and ISO 1043-1:2001 apply.

#### 3.1.1 Geometrical terms and definitions

##### 3.1.1.1 Nominal size

###### 3.1.1.1.1

###### nominal size (DN)

numerical designation of the size of a component, which is a convenient round number, approximately equal to the manufacturing dimensions, in millimetres (mm)

###### 3.1.1.1.2

###### nominal size (DN/OD)

nominal size, related to outside diameter

## EN ISO 15876-1:2003 (E)

### 3.1.1.2

#### **nominal outside diameter** ( $d_n$ )

specified diameter, in millimetres, assigned to a nominal size DN/OD

### 3.1.1.3

#### **outside diameter (at any point)** ( $d_e$ )

measured outside diameter through the cross section at any point of a pipe or spigot end of a fitting, rounded up to the nearest 0,1 mm

### 3.1.1.4

#### **mean outside diameter** ( $d_{em}$ )

measured length of the outer circumference of a pipe or spigot end of a fitting in any cross section divided by  $\pi$  ( $\approx 3,142$ ) rounded up to the nearest 0,1 mm

### 3.1.1.5

#### **minimum mean outside diameter** ( $d_{em,min}$ )

minimum value of the mean outside diameter as specified for a given nominal size

### 3.1.1.6

#### **maximum mean outside diameter** ( $d_{em,max}$ )

maximum value of the mean outside diameter as specified for a given nominal size

### 3.1.1.7

#### **mean inside diameter of socket** ( $d_{sm}$ )

arithmetical mean of two measured inside diameters perpendicular to each other at the midpoint of the socket length

### 3.1.1.8

#### **out-of-roundness** (ovality)

difference between the measured maximum outside diameter and the measured minimum outside diameter in the same cross-sectional plane of a pipe or spigot end of a fitting, or the difference between the measured maximum inside diameter and the measured minimum inside diameter in the same cross-sectional plane of a socket

### 3.1.1.9

#### **nominal wall thickness** ( $e_n$ )

numerical designation of the wall thickness of a component, approximately equal to the manufacturing dimension, in millimetres (mm)

### 3.1.1.10

#### **wall thickness (at any point)** ( $e$ )

measured wall thickness at any point around the circumference of a component, rounded up to the nearest 0,1 mm

### 3.1.1.11

#### **minimum wall thickness (at any point)** ( $e_{min}$ )

minimum wall thickness at any point around the circumference of a component, as specified

### 3.1.1.12

#### **maximum wall thickness (at any point)** ( $e_{max}$ )

maximum wall thickness at any point around the circumference of a component, as specified

### 3.1.1.13

#### **tolerance**

permitted variation of the specified value of a quantity expressed as the difference between the permitted maximum and permitted minimum value

### 3.1.1.14

#### **pipe series (S)**

dimensionless number for pipe designation and conforming to ISO 4065 [2]

NOTE According to EN ISO 15876 the pipe series S is used as a means for selecting pipe sizes for practical purposes (see EN ISO 15876-2:2003).