



SWEDISH
STANDARDS
INSTITUTE

SVENSK STANDARD
SS-EN 12101-10:2006

Fastställd 2006-10-19

Utgåva 1

**Brand och räddning – System och komponenter
för rök- och brandgaser –
Del 10: Strömförsörjning**

**Smoke and heat control systems –
Part 10: Power supplies**

ICS 13.220.99

Språk: engelska

Publicerad: december 2006

Europastandarden EN 12101-10:2005 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 12101-10:2005.

The European Standard EN 12101-10:2005 has the status of a Swedish Standard. This document contains the official English version of EN 12101-10:2005.

Uppllysningar om **sakinnehållet** i standarden lämnas av SIS, Swedish Standards Institute, telefon 08 - 555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar **allmänna uppllysningar** om svensk och utländsk standard.

Postadress: SIS Förlag AB, 118 80 STOCKHOLM
Telefon: 08 - 555 523 10. *Telefax:* 08 - 555 523 11
E-post: sis.sales@sis.se. *Internet:* www.sis.se

EUROPEAN STANDARD

EN 12101-10

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2005

ICS 13.220.99

English Version

Smoke and heat control systems - Part 10: Power supplies

Systèmes pour le contrôle des fumées et de la chaleur -
Partie 10 : Equipement d'alimentation en énergie

Rauch- und Wärmefreihaltung - Teil 10: Energieversorgung

This European Standard was approved by CEN on 26 August 2005.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

EN 12101-10:2005 (E)

Contents	Page
Foreword	4
Introduction.....	6
1 Scope	7
2 Normative references	7
3 Terms, definitions and abbreviations.....	8
3.1 Terms and definitions.....	8
3.2 Abbreviations	9
4 General requirements (electrical)	10
4.1 General	10
4.2 Batteries.....	11
4.3 Generator sets.....	11
5 General requirements (pneumatic).....	12
5.1 General	12
5.2 Power sources	12
6 Functions.....	15
6.1 Power supply from the primary power source (electrical).....	15
6.2 Power supply from the secondary power source (battery).....	15
6.3 Power supply from the secondary power source (generators).....	16
6.4 Recognition and indication of faults (electrical).....	17
6.5 Power supply from compressed gases.....	18
7 Materials, design and manufacture	20
7.1 Mechanical design	20
7.2 Electrical design	20
8 Classification.....	20
9 Documentation.....	21
9.1 User's documentation	21
9.2 Design documentation	22
10 Marking	22
10.1 General	22
10.2 Gas bottles	23
11 General test requirements.....	23
11.1 Standard atmospheric conditions for testing	23
11.2 Mounting and orientation	23
11.3 Electrical connection	23
11.4 Selection of tests	23
12 Tests	26
12.1 Electrical functional test.....	26
12.2 Pneumatic functional test.....	28
12.3 Test of the charger and the secondary power source	28
12.4 Cold (operational)	29
12.5 Damp heat, steady state (operational).....	30
12.6 Impact (operational).....	31
12.7 Vibration, sinusoidal (operational)	31
12.8 Damp heat, steady state (endurance).....	32
12.9 Vibration, sinusoidal (endurance).....	34

EN 12101-10:2005 (E)

12.10	Dry heat (operational)	34
12.11	SO₂ corrosion	35
12.12	Salt spray testing	37
12.13	Protection against water	38
12.14	Protection against solid foreign objects	38
12.15	EMC immunity tests (operational)	39
13	Evaluation of conformity	40
13.1	General	40
13.2	Initial type testing	40
13.3	Factory production control (FPC)	41
Annex A (informative) Summary of functions		45
Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU		
	Construction Products Directive	46
ZA.1	Scope and relevant characteristics	46
ZA.2	Procedure for attestation of conformity of power supply equipment	47
ZA.2.1	System of attestation of conformity	47
ZA.2.2	EC Certificate and Declaration of conformity	48
ZA.3	CE marking and labelling	49

EN 12101-10:2005 (E)

Foreword

This European Standard (EN 12101-10:2005) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2006, and conflicting national standards shall be withdrawn at the latest by April 2006.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this European Standard.

EN 12101 'Smoke and heat control systems' consists of the following:

- Part 1: Specification for smoke barriers,
- Part 2: Specification for natural smoke and heat exhaust ventilators,
- Part 3: Specification for powered smoke and heat exhaust ventilators,
- Part 4: Fire and smoke control installations – Kits,
- Part 6: Pressure differential systems – Kits,
- Part 7: Smoke control ducts,
- Part 8: Specifications for smoke control dampers,
- Part 9: Control panels,
- Part 10: Power supplies.

EN 12101 is included in a series of European Standards planned to cover also:

- Gas extinguishing systems (EN 12094 and EN ISO 14520),
- Sprinkler systems (EN 12259),
- Powder systems (EN 12416),
- Explosion protection systems (EN 26184),
- Foam systems (EN 13565),
- Hose systems (EN 671),
- Water spray systems.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic,

EN 12101-10:2005 (E)

Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

EN 12101-10:2005 (E)

Introduction

Smoke and heat control systems are used to protect people, buildings and/or building contents from the effects of smoke and heat in the event of fire. The most common systems are smoke and heat exhaust ventilation systems (SHEVS) and pressure differential systems.

Smoke and heat exhaust ventilation systems (SHEVS) create a smoke free layer above the floor by removing smoke and thus improve the conditions for the safe escape and/or rescue of people and animals and the protection of property and permit the fire to be fought while still in its early stages. They also exhaust hot gases released by a fire in the developing stage.

The use of smoke and heat exhaust ventilation systems to create smoke free areas beneath a buoyant smoke layer has become widespread. Their value in assisting in the evacuation of people from construction works, reducing fire damage and financial loss by preventing smoke logging, facilitating fire fighting, reducing roof temperatures and retarding the lateral spread of fire is firmly established. For these benefits to be obtained it is essential that smoke and heat exhaust ventilators operate fully and reliably whenever called upon to do so during their installed life. A heat and smoke exhaust ventilation system is a scheme of safety equipment intended to perform a positive role in a fire emergency.

Components for smoke and heat exhaust systems should be installed as part of a properly designed smoke and heat system.

Smoke and heat exhaust ventilation systems help to:

- keep the escape and access routes free from smoke;
- facilitate fire fighting operations by creating a smoke free layer;
- delay and/or prevent flashover and thus full development of the fire;
- protect buildings, equipment and furnishings;
- reduce thermal effects on structural components during a fire;
- reduce damage caused by thermal decomposition products and hot gases.

Pressure differential systems are used to either positively pressurise spaces separated from the fire or to depressurise the space containing the fire in order to limit or prevent the flow of smoke and heat into adjacent spaces. A typical use would be to pressurise an escape stair well in order to protect vertical means of escape.

Depending on the design of the system, natural or powered smoke and heat ventilation can be used in a smoke and heat control system.

Power supply equipment for a smoke and heat control system may be for pneumatic systems, low voltage or extra low voltage electrical systems, or a combination of any of these.

Smoke and heat control system power supplies may also provide power for day to day ventilation and for other fire safety equipment under fire conditions.

1 Scope

This European Standard specifies requirements and gives test methods for primary and secondary electrical and pneumatic power supply equipment, designed for use in smoke and heat control systems in buildings. It also provides for the evaluation of conformity of such equipment to the requirements of this European Standard.

NOTE A summary of functions is given in Annex A.

2 Normative references

The following referenced documents are indispensable for the application of this European Standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 286-1, *Simple unfired pressure vessels designed to contain air or nitrogen – Part 1: Pressure vessels for general purposes*

EN 1964-1, *Transportable gas cylinders – Part 1: Specification for the design and construction of refillable transportable seamless steel gas cylinders of water capacities from 0,5 litre up to and including 150 litres. Cylinders made of seamless steel with an R_m value of less than 1100 MPa*

prEN 12101-9, *Smoke and heat control systems – Part 9: Control panels*

EN 12205, *Transportable gas cylinders – Non-refillable metallic gas cylinders*

EN 13293, *Transportable gas cylinders – Specification for the design and construction of refillable transportable seamless normalized carbon manganese steel gas cylinders of water capacity up to 0,5 litre for compressed, liquefied and dissolved gases and up to 1 litre for carbon dioxide*

EN 50130-4, *Alarm systems – Part 4: Electromagnetic compatibility – Product family standard: Immunity requirements for components of fire, intruder and social alarm systems*

EN 60068-1, *Environmental testing – Part 1: General and guidance (IEC 60068-1:1988 + Corrigendum 1988 + A1:1992)*

EN 60068-2-1, *Environmental testing – Part 2-1: Test methods – Tests A: Cold (IEC 60068-2-1:1990)*

EN 60068-2-6, *Environmental testing – Part 2-6: Test methods – Test Fc: Vibration (sinusoidal) (IEC 60068-2-6:1990 + Corrigendum 1995)*

EN 60068-2-47, *Environmental testing – Part 2-47: Test methods – Mounting of components, equipment and other articles for vibration, impact and similar dynamic tests (IEC 60068-2-47:1999)*

EN 60068-2-52:1996, *Environmental testing – Part 2-52 – Test methods – Test Kb, salt mist cyclic (sodium chloride solution) (IEC 60068-2-52:1996)*

EN 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests (IEC 60068-2-75:1997)*

EN 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state (IEC 60068-2-78:2001)*

EN 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements (IEC 60204-1:1997)*

EN 60529, *Degrees of protection provided by enclosures (IP code) (IEC 60529:1989)*

EN 12101-10:2005 (E)

EN ISO 6988, *Metallic and other non-organic coatings – Sulphur dioxide test with general condensation of moisture (ISO 6988:1985)*

EN ISO 9001:2000, *Quality management systems – Requirements (ISO 9001:2000)*

EN ISO 12100-1, *Safety of machinery – Basic concepts, general principles for design – Part 1: Basic terminology, methodology (ISO 12100-1:2003)*

EN ISO 12100-2, *Safety of machinery – Basic concepts, general principles for design – Part 2: Technical principles (ISO 12100-2:2003)*

ISO 8528-1, *Reciprocating internal combustion engine driven alternating current generating sets – Part 1: Application, ratings and performance*

ISO 8528-2, *Reciprocating internal combustion engine driven alternating current generating sets – Part 2: Engines*

ISO 8528-3, *Reciprocating internal combustion engine driven alternating current generating sets – Part 3: Alternating current generators for generating sets*

ISO 8528-4, *Reciprocating internal combustion engine driven alternating current generating sets – Part 4: Control gear and switch gear*

ISO 8528-5:1993, *Reciprocating internal combustion engine driven alternating current generating sets – Part 5: Generating sets*

ISO 8528-6, *Reciprocating internal combustion engine driven alternating current generating sets – Part 6: Test methods*

ISO 8528-7, *Reciprocating internal combustion engine driven alternating current generating sets – Part 7: Technical declarations for specification and design*

ISO 8528-10, *Reciprocating internal combustion engine driven alternating current generating sets – Part 10: Measurement of airborne noise by the enveloping surface method*

ISO 8528-12:1997, *Reciprocating internal combustion engine driven alternating current generating sets – Part 12: Emergency power supply to safety devices*

ISO 8573-1, *Compressed air for general use – Part 1: Contaminants and purity classes*

Guideline 84/525/EWG of the advice from 17 September 1984 for the adjustment of the legislation of the member states over smooth gas bottles from steel

ADR 2003, *The European Agreement concerning the International Carriage of Dangerous Goods by Road (ADR)*

3 Terms, definitions and abbreviations

For the purposes of this European Standard, the following terms, definitions and abbreviations apply.

3.1 Terms and definitions

3.1.1

final voltage

lowest recommended voltage to which a battery should be discharged

NOTE The final voltage is specified by the battery manufacturer.

3.1.2

$I_{\max a}$
maximum standby current

3.1.3

$I_{\max b}$
maximum short duration current

3.1.4

multiple use gas bottle

gas bottle that is held open to the system and can operate the system a number of times before it has to be replaced or refilled

3.1.5

power supply equipment

either a source or store of power or a means of automatically switching between separate power sources

3.1.6

primary power source

power supply that is used whenever it is available

3.1.7

secondary power source

power supply that automatically replaces the primary power source in the event of its failure

3.1.8

single use gas bottle

gas bottle that remains sealed until pierced for once only emergency use

3.1.9

smoke and heat control system

arrangement of components installed in a building to limit the effects of smoke and heat from a fire

3.1.10

smoke and heat exhaust ventilation system (SHEVS)

system comprising components which together exhaust smoke and heat to establish a buoyant layer of warm gases above cooler, cleaner air

3.1.11

smoke and heat exhaust ventilator (SHEV)

device specially designed to move smoke and hot gases out of the building under conditions of fire

3.2 Abbreviations

p.s.e.: power supply equipment

c.p.: control panel