

SVENSK STANDARD

SS-EN 54-29:2015

Fastställt/Approved: 2015-04-12
Publicerad/Published: 2015-04-14
Utgåva/Edition: 1
Språk/Language: engelska/English
ICS: 13.220.20

Brand och räddning – Branddetekterings- och brandlarmsystem – Del 29: Flersensordetektorer av punkttyp med kombination av sensorer för rök och värme

Fire detection and fire alarm systems – Part 29: Multi-sensor fire detectors – Point detectors using a combination of smoke and heat sensors

This preview is downloaded from www.sis.se. Buy the entire standard via <https://www.sis.se/std-8013679>

Standarder får världen att fungera

SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.

Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på www.sis.se eller ta kontakt med oss på tel 08-555 523 00.



Standards make the world go round

SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.

Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

If you want to know more about SIS, or how standards can streamline your organisation, please visit www.sis.se or contact us on phone +46 (0)8-555 523 00



Europastandarden EN 54-29:2015 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 54-29:2015.

The European Standard EN 54-29:2015 has the status of a Swedish Standard. This document contains the official English version of EN 54-29:2015.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Uppllysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna uppllysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

Denna standard är framtagen av kommittén för Branddetektorer, brandlarmsystem, SIS/TK 360/AG 2.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på www.sis.se - där hittar du mer information.

EUROPEAN STANDARD

EN 54-29

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2015

ICS 13.220.20

English Version

Fire detection and fire alarm systems - Part 29: Multi-sensor fire detectors - Point detectors using a combination of smoke and heat sensors

Systèmes de détection et d'alarme incendie - Partie 29 :
DéTECTEURS d'incendie multi-capteurs - DéTECTEURS ponctuels
utilisant une combinaison de capteurs de fumée et de
chaleur

Brandmeldeanlagen - Teil 29: Mehrfachsensor-
Brandmelder - Punktförmige Melder mit kombinierten
Rauch- und Wärmesensoren

This European Standard was approved by CEN on 15 February 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	6
Introduction	8
1 Scope	9
2 Normative references	9
3 Terms and definitions	10
4 Requirements	10
4.1 General.....	10
4.2 Nominal activation conditions/sensitivity	10
4.2.1 Individual alarm indication	10
4.2.2 Response to slowly developing fires.....	10
4.2.3 Repeatability of smoke response.....	11
4.2.4 Directional dependence of smoke response	11
4.2.5 Directional dependence of heat response	11
4.2.6 Lower limit of heat response	11
4.2.7 Reproducibility of smoke response.....	11
4.2.8 Reproducibility of heat response.....	11
4.2.9 Air movement.....	11
4.2.10 Dazzling	11
4.3 Operational reliability	11
4.3.1 Connection of ancillary devices.....	11
4.3.2 Monitoring of detachable detectors.....	11
4.3.3 Manufacturer's adjustments	12
4.3.4 On-site adjustment of response behaviour	12
4.3.5 Protection against the ingress of foreign bodies.....	12
4.3.6 Software controlled detectors	12
4.4 Tolerance to supply parameters	13
4.4.1 Variation in supply parameters	13
4.5 Performance parameters under fire conditions	14
4.5.1 Fire sensitivity.....	14
4.6 Durability of nominal activation conditions/sensitivity	14
4.6.1 Temperature resistance	14
4.6.2 Humidity resistance.....	14
4.6.3 Shock and vibration resistance.....	14
4.6.4 Electrical stability	15
4.6.5 Resistance to chemical agents	15
5 Test and assessment and sampling methods	15
5.1 General.....	15
5.1.1 Atmospheric conditions for tests	15
5.1.2 Operating conditions for tests	15
5.1.3 Mounting arrangements.....	15
5.1.4 Tolerances	16
5.1.5 Measurement of smoke response value	16
5.1.6 Measurement of heat response value	16
5.1.7 Provision for tests	17
5.1.8 Test schedule.....	17
5.2 Nominal activation conditions/sensitivity	18
5.2.1 Individual alarm indication	18

5.2.2	Response to slowly developing fires	19
5.2.3	Repeatability of smoke response	19
5.2.4	Directional dependence of smoke response	19
5.2.5	Directional dependence of heat response	20
5.2.6	Lower limit of heat sensitivity	20
5.2.7	Reproducibility of smoke response	21
5.2.8	Reproducibility of heat response	21
5.2.9	Air movement.....	22
5.2.10	Dazzling	22
5.3	Operational reliability.....	23
5.3.1	Connection of ancillary devices	23
5.3.2	Monitoring of detachable detectors	23
5.3.3	Manufacturer's adjustments.....	23
5.3.4	On-site adjustment of behaviour	23
5.3.5	Protection against the ingress of foreign bodies	23
5.3.6	Software controlled devices.....	23
5.4	Tolerance to supply parameters	24
5.4.1	Variation in supply parameters.....	24
5.5	Performance parameters under fire conditions	24
5.5.1	Fire sensitivity	24
5.6	Durability of nominal activation conditions/sensitivity.....	26
5.6.1	Temperature resistance	26
5.6.2	Humidity resistance	28
5.6.3	Shock and vibration resistance	30
5.6.4	Electrical stability.....	34
5.6.5	Resistance to chemical agents	35
6	Assessment and verification of constancy of performance (AVCP)	37
6.1	General	37
6.2	Type testing	37
6.2.1	General	37
6.2.2	Test samples, testing and compliance criteria	38
6.2.3	Test reports.....	38
6.3	Factory production control (FPC).....	38
6.3.1	General	38
6.3.2	Requirements.....	39
6.3.3	Product specific requirements.....	41
6.3.4	Initial inspection of factory and FPC	42
6.3.5	Continuous surveillance of FPC	42
6.3.6	Procedure for modifications	42
6.3.7	One-off products, pre-production products, (e.g. prototypes) and products produced in very low quantities	43
7	Classification and designation	43
8	Marking, Labelling and Packaging	44
Annex A	(normative) Smoke tunnel for smoke response values	45
Annex B	(normative) Test aerosol for smoke response value measurements	46
Annex C	(normative) Smoke measuring instruments	47
C.1	Obscuration meter.....	47
C.2	Measuring ionization chamber (MIC).....	47
Annex D	(normative) Heat tunnel for heat response value	51
Annex E	(normative) Apparatus for dazzling test	52
Annex F	(informative) Apparatus for impact test.....	54

SS-EN 54-29:2015 (E)

Annex G (normative) Fire test room	56
Annex H (normative) Open wood fire (TF1)	58
H.1 Fuel	58
H.2 Arrangement	58
H.3 Method of ignition	58
H.4 Variables	58
H.5 End-of-test condition	58
H.6 Test validity criteria	59
Annex I (normative) Smouldering (pyrolysis) wood fire (TF2)	61
I.1 Fuel	61
I.2 Hotplate	61
I.3 Arrangement	61
I.4 Heating rate	61
I.5 End-of-test condition	61
I.6 Test validity criteria	61
Annex J (normative) Glowing smouldering cotton fire (TF3)	65
J.1 Fuel	65
J.2 Arrangement	65
J.3 Ignition	66
J.4 End-of-test condition	67
J.5 Test validity criteria	67
Annex K (normative) Open plastics (polyurethane) fire (TF4)	69
K.1 Fuel	69
K.2 Conditioning	69
K.3 Arrangement	69
K.4 Ignition	69
K.5 Method of ignition	69
K.6 End-of-test condition	69
K.7 Test validity criteria	69
Annex L (normative) Liquid (heptane) fire (TF5)	71
L.1 Fuel	71
L.2 Arrangement	71
L.3 Ignition	71
L.4 End-of-test condition	71
L.5 Test validity criteria	71
Annex M (normative) Low temperature black smoke (decalene) liquid fire (TF8)	73
M.1 Fuel	73
M.2 Arrangement	73

M.3	Ignition	73
M.4	End-of-test condition	73
M.5	Test validity criteria	73
Annex N	(informative) Information concerning the construction of the smoke tunnel	75
Annex O	(informative) Construction of the heat tunnel	77
Annex P	(informative) Information concerning test procedures and requirements for the response to slowly developing fires	80
Annex Q	(informative) Information concerning the construction of the measuring ionization chamber	84
Annex ZA	(informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation	86
ZA.1	Scope and relevant characteristics	86
ZA.2	Procedure for assessment and verification of constancy of performance (AVCP) of point detectors using a combination of smoke and heat sensors	88
ZA.3	CE marking and labelling	92
	Bibliography	96

SS-EN 54-29:2015 (E)

Foreword

This document (EN 54-29:2015) has been prepared by Technical Committee CEN/TC 72 "Fire detection and fire alarm systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2015, and conflicting national standards shall be withdrawn at the latest by January 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports the basic requirements of Regulation (EU) 305/2011.

For relationship with EU Regulations, see informative Annex ZA which is an integral part of this document.

EN 54, *Fire detection and fire alarm systems*, consists of the following parts:

- *Part 1: Introduction*
- *Part 2: Control and indicating equipment*
- *Part 3: Fire alarm devices – Sounders*
- *Part 4: Power supply equipment*
- *Part 5: Heat detectors – Point detectors*
- *Part 7: Smoke detectors – Point detectors using scattered light, transmitted light or ionization*
- *Part 10: Flame detector – Point detectors*
- *Part 11: Manual call points*
- *Part 12: Smoke detectors – Line detector using an optical light beam*
- *Part 13: Compatibility assessment of system components*
- *Part 14: Technical Specification: Guidelines for planning, design, installation, commissioning, use and maintenance*
- *Part 16: Voice alarm control and indicating equipment*
- *Part 17: Short circuit isolators*
- *Part 18: Input/output devices*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Alarm transmission and fault warning routing equipment*
- *Part 22: Resettable Line-type heat detectors*
- *Part 23: Fire alarm devices – Visual alarms*

- *Part 24: Components of voice alarm systems – Loudspeakers*
- *Part 25: Components using radio links and system requirements*
- *Part 26: Point fire detectors using carbon monoxide sensors*
- *Part 27: Duct smoke detectors*
- *Part 28: Non-resettable (digital) line type heat detectors*
- *Part 29: Point detectors using a combination of smoke and heat sensors*
- *Part 30: Point detectors using a combination of carbon monoxide and heat sensors*
- *Part 31: Point detectors using a combination of smoke, carbon monoxide and optionally heat sensors*
- *Part 32: Guidelines for the planning, design, installation, commissioning, use and maintenance of voice alarm systems*

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to <http://www.cen.eu/Pages/default.aspx>.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

SS-EN 54-29:2015 (E)

Introduction

Multi-sensor fire detectors combining smoke and heat sensors complying with this document are general purpose fire detectors. Multi-sensor fire detectors can be used to achieve

- a high stability against deceptive phenomena,
- a response to a broad range of fires.

Compared to the standards for single phenomenon detectors, additional environmental tests were included to demonstrate a higher stability.

The response to a broad range of fires is shown by including the test fires TF1 and TF8 in addition to the test fires TF2 to TF5 which are used for detectors complying with EN 54-7.

The performance of single sensor components of a multi-sensor fire detector need not comply with the standards for single phenomena fire detectors (EN 54-5, EN 54-7) however the combined performance does need to meet the requirements of this standard.

1 Scope

This European Standard specifies requirements, test methods and performance criteria for point-type multi-sensor fire detectors for use in fire detection systems installed in buildings (see EN 54-1:2011), incorporating in one mechanical enclosure at least one optical or ionization smoke sensor and at least one heat sensor. The overall fire detection performance is determined utilizing the combination of the detected phenomena.

This European Standard provides for the assessment and verification of constancy of performance (AVCP) of point detectors using a combination of smoke and heat sensors to this European Standard.

Point detectors using a combination of smoke and heat sensors having special characteristics suitable for the detection of specific fire risks are not covered by this European Standard. The performance requirements for any additional functions are beyond the scope of this European Standard (e.g. additional features or enhanced functionality for which this European Standard does not define a test or assessment method).

NOTE Certain types of detector contain radioactive materials. The national requirements for radiation protection differ from country to country and they are not specified in this European Standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1:2011, *Fire detection and fire alarm systems - Part 1: Introduction*

EN 54-5:2000, *Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors*

EN 54-5:2000/A1:2002, *Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors*

EN 50130-4:2011, *Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 60068-1:1994, *Environmental testing - Part 1: General and guidance (IEC 60068-1:1988)*

EN 60068-2-1:2007, *Environmental testing - Part 2-1: Tests - Test A: Cold (IEC 60068-2-1:2007)*

EN 60068-2-6:2008, *Environmental testing - Part 2-6: Tests - Test Fc: Vibration (sinusoidal) (IEC 60068-2-6:2008)*

EN 60068-2-27:2009, *Environmental testing - Part 2-27: Tests - Test Ea and guidance: Shock (IEC 60068-2-27:2009)*

EN 60068-2-30:2005, *Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle) (IEC 60068-2-30:2005)*

EN 60068-2-42:2003, *Environmental testing - Part 2-42: Tests - Test Kc: Sulphur dioxide test for contacts and connections (IEC 60068-2-42:2003)*

EN 60068-2-78:2013, *Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state (IEC 60068-2-78:2012)*

ISO 209:2007, *Aluminium and aluminium alloys — Chemical composition*

SS-EN 54-29:2015 (E)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 54-1:2011 and the following apply.

- 3.1 non-volatile memory**
memory element which does not require the presence of an energy source for the retention of its content
- 3.2 site specific data**
alterable data required for the detector to operate in a defined detector configuration
- 3.3 smoke response value**
aerosol density in the proximity of a test specimen at the moment that it generates a reference signal in a smoke tunnel
- 3.4 heat response value**
temperature in the proximity of a test specimen at the moment that it generates a reference signal in a heat tunnel
- 3.5 sensor**
transducer, which is assigned to be receptive to one fire phenomenon and converts its information into an electrical output

4 Requirements

4.1 General

In order to comply with this standard, the detector shall meet the requirements of Clause 4, which shall be verified by visual inspection, engineering assessment or shall be tested as described in Clause 5 and shall meet the requirements of the tests.

4.2 Nominal activation conditions/sensitivity

4.2.1 Individual alarm indication

The detector shall be provided with an integral red visual indicator, by which the individual detector that released an alarm, can be identified, until the alarm condition is reset. Where other conditions of the detector can be visually indicated, they shall be clearly distinguishable from the alarm indication, except when the detector is switched into a service mode. For detachable detectors, the indicator may be integral with the base or the detector head. The visual indicator shall be visible from a distance of 6 m directly below the detector, in an ambient light intensity up to 500 lux when assessed as described in 5.2.1.

NOTE The alarm condition is reset manually at the control and indicating equipment (see EN 54–2:1997 as amended by EN 54–2:1997/A1:2006).

4.2.2 Response to slowly developing fires

The detector may incorporate provision for “drift compensation”, for example to compensate for sensor drift due to the build up of dirt in the detector, If such drift compensation is included, then it shall not lead to a significant reduction in the detector's sensitivity to slowly developing fires when assessed as specified in 5.2.2.

4.2.3 Repeatability of smoke response

The detector shall have stable behaviour with respect to its sensitivity to smoke after a number of alarm conditions. To confirm this, the detector shall be assessed in accordance with 5.2.3.

4.2.4 Directional dependence of smoke response

The sensitivity of the detector to smoke shall not be unduly dependent on the direction of airflow around it. To confirm this, the detector shall be assessed in accordance with 5.2.4.

4.2.5 Directional dependence of heat response

The heat sensitivity of the detector shall not be unduly dependent on the direction of airflow around it. To confirm this, the detector shall be assessed in accordance with 5.2.5.

4.2.6 Lower limit of heat response

The detector shall not be more sensitive to heat alone, without the presence of smoke, than is permitted in EN 54-5:2000 as amended by EN 54-5:2000/A1:2002. To confirm this, the detector shall be assessed in accordance with 5.2.6.

4.2.7 Reproducibility of smoke response

The sensitivity of the detector to smoke shall not vary unduly from specimen to specimen. To confirm this, the detector shall be assessed in accordance with 5.2.7.

4.2.8 Reproducibility of heat response

The heat sensitivity of the detector shall not vary unduly from specimen to specimen. To confirm this, the detector shall be assessed in accordance with 5.2.8.

4.2.9 Air movement

The sensitivity of the detector shall not be unduly affected by the rate of the airflow and that it is not unduly prone to false alarms in draughts or in short gusts. To confirm this, the detector shall be assessed in accordance with 5.2.9.

4.2.10 Dazzling

The sensitivity of the detector shall not be unduly influenced by the close proximity of artificial light sources. To confirm this, the detector shall be assessed in accordance with 5.2.10. This test is only applicable to detectors using optical smoke sensors, as ionization chamber detectors are considered unlikely to be influenced.

4.3 Operational reliability

4.3.1 Connection of ancillary devices

Where the detector provides for connections to ancillary devices (e.g. remote indicators, control relays), open- or short-circuit failures of these connections shall not prevent the correct operation of the detector.

4.3.2 Monitoring of detachable detectors

For detachable detectors, means shall be provided for a remote monitoring system (e.g. the control and indicating equipment) to detect the removal of the head from the base, in order to give a fault signal.

SS-EN 54-29:2015 (E)

4.3.3 Manufacturer's adjustments

It shall not be possible to change the manufacturer's settings except by special means (e.g. the use of a special code or tool) or by breaking or removing a seal.

4.3.4 On-site adjustment of response behaviour

If there is provision for on-site adjustment of the response behaviour of the detector then:

- a) for each setting at which the manufacturer claims compliance with this standard, the detector shall comply with the requirements of this standard, and access to the adjustment means shall only be possible by the use of a code or special tool or by removing the detector from its base or mounting;
- b) any setting(s) at which the manufacturer does not claim compliance with this standard, shall only be accessible by the use of a code or special tool, and it shall be clearly marked on the detector or in the associated data, that if these setting(s) are used, the detector does not comply with the standard.

These adjustments may be carried out at the detector or at the control and indicating equipment.

4.3.5 Protection against the ingress of foreign bodies

The detector shall be so designed that a sphere of diameter $(1,3 \pm 0,05)$ mm cannot pass into the smoke sensor chamber(s).

NOTE This requirement is intended to restrict the access of insects into the sensitive parts of the detector. It is known that this requirement is not sufficient to prevent the access of all insects; however, it is considered that extreme restrictions on the size of access holes may introduce the danger of clogging by dust etc. It may therefore be necessary to take other precautions against false alarms due to the entry of small insects.

4.3.6 Software controlled detectors

4.3.6.1 General

For detectors which rely on software control in order to fulfil the requirements of this standard, the requirements of 4.3.6.2, 4.3.6.3 and 4.3.6.4 shall be met.

4.3.6.2 Software documentation

4.3.6.2.1 Design overview

The manufacturer shall submit documentation which gives an overview of the software design. This documentation shall be in sufficient detail for the design to be inspected for compliance with this standard and shall include at least the following:

- a) a functional description of the main program flow (e.g. as a flow diagram or structogram) including:
 - 1) a brief description of the modules and the functions that they perform;
 - 2) the way in which the modules interact;
 - 3) the overall hierarchy of the program;
 - 4) the way in which the software interacts with the hardware of the detector;
 - 5) the way in which the modules are called, including any interrupt processing.

- b) a description of which areas of memory are used for the various purposes (e.g. the program, site specific data and running data);
- c) a designation, by which the software and its version can be uniquely identified.

4.3.6.2.2 Design detail

The manufacturer shall have available detailed design documentation, which only needs to be provided if required by the testing authority. It shall comprise at least the following:

- a) an overview of the whole system configuration, including all software and hardware components;
- b) a description of each module of the program, containing at least:
 - 1) the name of the module;
 - 2) a description of the tasks performed;
 - 3) a description of the interfaces, including the type of data transfer, the valid data range and the checking for valid data.
- c) full source code listings, as hard copy or in machine-readable form (e.g. ASCII-code), including all global and local variables, constants and labels used, and sufficient comment for the program flow to be recognized;
- d) details of any software tools used in the design and implementation phase (e.g. CASE-tools, compilers).

4.3.6.3 Software design

In order to ensure the reliability of the detector, the following requirements for software design shall apply:

- a) the software shall have a modular structure;
- b) the design of the interfaces for manually and automatically generated data shall not permit invalid data to cause error in the program operation;
- c) the software shall be designed to avoid the occurrence of deadlock of the program flow.

4.3.6.4 The storage of programs and data

The program necessary to comply with this standard and any pre-set data, such as manufacturer's settings, shall be held in non-volatile memory. Writing to areas of memory containing this program and data shall only be possible by the use of some special tool or code and shall not be possible during normal operation of the detector.

Site-specific data shall be held in memory which will retain data for at least two weeks without external power to the detector, unless provision is made for the automatic renewal of such data, following loss of power, within 1 h of power being restored.

4.4 Tolerance to supply parameters

4.4.1 Variation in supply parameters

Within the specified range(s) of the supply parameters, the sensitivity of the detector shall not be unduly dependent on these parameters (e.g. voltage). To confirm this, the detector shall be assessed in accordance with 5.4.1.

SS-EN 54-29:2015 (E)

4.5 Performance parameters under fire conditions

4.5.1 Fire sensitivity

The detector shall have adequate sensitivity to incipient type fires that may occur in buildings. To confirm this, the detector shall be assessed in accordance with 5.5.1.

4.6 Durability of nominal activation conditions/sensitivity

4.6.1 Temperature resistance

4.6.1.1 Dry heat (operational)

The detector shall function correctly at high ambient temperatures. To confirm this, the detector shall be assessed in accordance with 5.6.1.1.

4.6.1.2 Cold (operational)

The detector shall function correctly at low ambient temperatures. To confirm this, the detector shall be assessed in accordance with 5.6.1.2.

4.6.2 Humidity resistance

4.6.2.1 Damp heat, cyclic (operational)

The detector shall function correctly at a high level of relative humidity with short period of condensation. To confirm this, the detector shall be assessed in accordance with 5.6.2.1.

4.6.2.2 Damp heat steady-state (endurance)

The detector shall be capable of withstanding long term exposure to a high level of continuous humidity. To confirm this, the detector shall be assessed in accordance with 5.6.2.2.

4.6.3 Shock and vibration resistance

4.6.3.1 Shock (operational)

The detector shall function correctly when submitted to mechanical shocks which are likely to occur in the service environment. To confirm this, the detector shall be assessed in accordance with 5.6.3.1.

4.6.3.2 Impact (operational)

The detector shall function correctly when submitted to mechanical impacts which it may sustain in the normal service environment. To confirm this, the detector shall be assessed in accordance with 5.6.3.2.

4.6.3.3 Vibration, sinusoidal (operational)

The detector shall function correctly when submitted to vibration at levels appropriate to its normal service environment. To confirm this, the detector shall be assessed in accordance with 5.6.3.3.

4.6.3.4 Vibration, sinusoidal (endurance)

The detector shall be capable of withstanding long exposure to vibration at levels appropriate to the service environment. To confirm this, the detector shall be assessed in accordance with 5.6.3.4.

4.6.4 Electrical stability

4.6.4.1 EMC, immunity (operational)

The detector shall operate correctly when submitted to electromagnetic interference. To confirm this, the detector shall be assessed in accordance with 5.6.4.1.

4.6.5 Resistance to chemical agents

4.6.5.1 SO₂ corrosion (endurance)

The detector shall be capable of withstanding the corrosive effects of sulphur dioxide as an atmospheric pollutant. To confirm this, the detector shall be assessed in accordance with 5.6.5.1.

5 Test and assessment and sampling methods

5.1 General

5.1.1 Atmospheric conditions for tests

Unless otherwise stated in a test procedure, the testing shall be carried out after the test specimen has been allowed to stabilize in the standard atmospheric conditions for testing as described in EN 60068-1:1994 as follows:

- temperature: (15 to 35) °C;
- relative humidity: (25 to 75) %;
- air pressure: (86 to 106) kPa.

If variations in these parameters have a significant effect on a measurement, then such variations should be kept to a minimum during a series of measurements carried out as part of one test on one specimen.

5.1.2 Operating conditions for tests

If a test method requires a specimen to be operational, then the specimen shall be connected to a suitable supply and monitoring equipment with characteristics as required by the manufacturer's data. Unless otherwise specified in the test method, the supply parameters applied to the specimen shall be set within the manufacturer's specified range(s) and shall remain substantially constant throughout the tests. The value chosen for each parameter shall normally be the nominal value, or the mean of the specified range. If a test procedure requires a specimen to be monitored to detect any alarm or fault signals, then connections shall be made to any necessary ancillary devices (e.g. through wiring to an end-of-line device for conventional detectors) to allow an alarm or fault signal to be recognized. The details of the supply and monitoring equipment and the alarm criteria used shall be given in the test report.

5.1.3 Mounting arrangements

The specimen shall be mounted by its normal means of attachment and in its normal orientation in accordance with the manufacturer's instructions. If these instructions describe more than one method of mounting, or more than one acceptable orientation, for each test the method evaluated to be most unfavourable shall be chosen.